



**Zone 0** is inside the bath or shower itself. Any fitting used in this zone must be low voltage, (max 12v) and be rated at least **IP67** which is total immersion proof.

**Zone 1** is the area above the bath or shower to a height of 2.25m from the floor. In this zone a minimum rating of IP45 is required, but it is generally accepted that **IP65** is to be used.

**Zone 2** is an area stretching 0.6m outside the perimeter of the bath and to a height of 2.25m from the floor. In this zone an IP rating of at least **IP44** is required.

**Outside Zones** are anywhere outside zones 0, 1 & 2 (subject to specific limits) and where no water jet is likely to be used. There are no special IP requirements in this zone,